



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 4408

Dated: 11/12/2023

To,

Authorised Signatory,
Stri Shakti NGO,
Kh. No. 444/447, Alipur Garhi,
Delhi-110036.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Stri Shakti NGO located at Kh. No. 444/ 447, Alipur Garhi, Delhi- 110036.

Sir,

This has reference to your letter number SS/DEL/301/2023-24 dated 22/11/2023 received via outdoor diary number 9018 dated 22/11/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 01.12.2023 in presence of Smt. Pupinder Kaur to verify the fire safety arrangements provided there in.

During the course of inspection it was observed that the building comprised of Ground Floor only. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. Smoke ventilation is system not provided.
2. First Aid Hose Reel is not provided.
3. MOEFA is not provided.
4. Internal hydrant is not provided.
5. Terrace level pump of 450 lpm capacity is not provided.
6. An overhead water storage tank of 20,000 lts capacity is not provided.
7. Exit signage is not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate, till such time, issuance of fire safety certificate is not considered & rejected.

Yours Faithfully


(Atul Garg)

Director

Ph. 011-23414000

ou n
3/12