



No. F6 /DFS/MS/EH/SZ/2023/ 665.

Dated: 12/12/23

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

**Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Coffee Day Global (Restaurant)
Situated at Shop No.A-10, Lajpat Nagar-II, New Delhi.**

Sir,

with reference to the MHA online application ID no. 2023112718937 dated 23.11.2023 on the subject cited above, it is informed that the said restaurant was inspected by officer concerned of this department on 05.12.2023 in the presence of Mrs. Shalu (Crew Master) and it was observed that the restaurant is running at Upper Ground of the building which is comprised of Lower Ground + Upper Ground + 3 upper floors. During the inspection following shortcomings were observed:

1. 2 nos. of door (exit) width of 1.50 meters found not provided. Only single door of 1.0 meter width is available.
2. 4 nos. of Fire extinguishers found not provided. Only 2 nos. of fire extinguishers are available on site.
3. Hose reel & internal hydrant found not provided.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found not provided.
5. Fire pump having capacity 450 LPM & head 40 m not provided.
6. Overhead tank capacity 20,000 liters exclusively for firefighting found not provided.
7. Exit signages found not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

05/12/23