

c/91

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/GH/SZ/2023/ 594

Dated: 12/12/2023

To

The Owner/Occupier
M/s. Crystal Palace guest house, 22/7,
Old Rajinder Nagar, New Delhi- 110060.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Crystal Palace guest house located at 22/7, Old Rajinder Nagar, New Delhi- 110060.

Sir,

Please refer to your Online Application Id. 2023111918648 dated 23.11.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 07.12.2023 in the presence of Sh. Bharamdev (Manager), to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts. etc. found provided. However the following shortcomings were observed:-

1. Ventilation system found removed in basement.
2. Terrace fire pump capacity of 450 LPM found provided but not in auto mode.
3. Exit Singes found removed.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.