

C/92.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2023/ 592

Dated: 12/12/2023

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of M/s Hotel India, 691, Queen Garden Bagh Deewar, Fatch Puri, Delhi-06.


Sir,

This has reference to online application I.D. no. 2023112618904 dated 26.11.2023 on the subject cited above. It is informed that the guest house was inspected by the officer concerned of this department on 02.12.2023 in the presence Mr. Dharam Singh (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire extinguishers found non functional.
2. Fire pump not in auto start mode.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

u/c  
07/12

Copy to:-

The Manager, M/s Hotel India, 691, Queen Garden Bagh Deewar, Fatch Puri, Delhi-06.