

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2023/ 595.

Dated: |2|12|2023

To

The Joint Commissioner of Police (Licensing), 1<sup>st</sup> Floor, Police Station Defence Colony, New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Hotel Le-Mem situated at 741-745, Church Mission Road, Fatehpuri, Delhi.

Sir,

This has reference to online application I.D. no. 2023112418845 dated 24.11.2023 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned of this department on 02.12.2023 in the presence of Mr. Pawan Gupta (Owner). During inspection, following shortcomings were observed:

- 1. Fire check doors which are required as per gazette notification dated 27.05.2019, not provided.
- 2. Fire pump not in auto start mode.
- 3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-.

The Manager, Hotel Le-Mem at 741-745, Church Mission Road, Fatehpuri, Delhi-06.