

c/s

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 664

Dated: 12/12/23

To,

The Manager,
M/s Naivedyam, Shop No. S-26,
Ground Floor, Ajay Enclave, Subhash Nagar, Delhi-110018.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Naivedyam, Shop No. S-26, Ground Floor, Ajay Enclave, Subhash Nagar, Delhi-110018.

Sir,

Please refer to your letter ID No. 2023111818623 dated 18/11/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Umesh (Manager) was present and it was observed that the building is comprised of Lower basement, Upper basement, Ground floor plus four upper floors but Eating house is running at ground floor only and have following shortcomings:-

1. An additional exit shall be provided of 1.5 m.
2. One First aid hose reel & Hydrant shall be extended to cover the eating house.
3. Exits signage's are provided but not sufficient.


In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police, 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi-110064