

c/s

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/EH/NDZ/2023/ 666

Dated: 13/12/2023

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub: - Regarding issuance of Fire Safety Certificate in respect of M/S Sagar Ratna Restaurant Pvt. Ltd. at Shop No. 13, Alipur Road, Civil Lines, Delhi 110054.**

Sir,

This has a reference to online application ID No. 2023111718581 dated 20.11.2023 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the team of officers concerned of this department on 07.12.2023 in presence of Mr. Pawan (Project Manager) and it was observed that building is comprised of Ground + 02 upper floor but restaurant running at 1<sup>st</sup> floor only. During inspection, following shortcomings were observed:

1. 02 number of staircase having width 1.50 mtr. must be provided, hence additional staircase having width of 1.5 mtr. is required.
2. First aid hose reels not provided.
3. Hydrant system not provided.
4. Fire pump not in auto start mode.
5. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Atul Garg)  
Director  
Delhi Fire Service o/c  
Tel: 0112341400

20/12/2023

**Copy to:-**

The Manager,  
Sagar Ratna Restaurant Pvt. Ltd. at Shop No. 13, Alipur Road, Civil Lines, Delhi 110054.