

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/NDZ/Metro/2023/ 4429

Dated: 13/12/2023

To,

Sh. Malay Saha, General Manager (E&M)  
Delhi Metro Rail Corporation Limited,  
Metro Bhawan, Connaught Place, New Delhi-110001.

**Sub: Regarding issue of Fire Safety Certificate in respect of Kashmere Gate Metro Station (Line-1), Kashmere Gate, Delhi.**

Sir,

This has reference to your letter no. DMRC/OAM/Fire/NOC/L-1/2023/10/03 dated 30.10.2023 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on dated 08.12.2023 in the presence of Mr. Ashish (Fire Inspector) and observed that the building/ premises have complied the shortcomings issued vide letter no. F6/DFS/MS/Business/NDZ/2022/2942 dated 23.11.2022(copy enclosed) except following which still exists:-

1. A bottleneck situation has been created in exit pathway of staircase towards gate no. 4 due to Chaayos Kiosk.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier

Yours faithfully,

(Arul Garg)  
Director  
Delhi Fire Service  
Tel: 011- 23414000  
o/c

**Copy to:-**

The Commissioner,  
Municipal Corporation of Delhi, Dr. SPM Civic Centre, Near Kamla Market, Delhi-02.