

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Ind./2023/SZ/4431
To

Dated: 13./12./2023

The Authorized Signatory,
Exhibitions India Pvt LTD,
Plot No C- 103, Okhla Industrial Estate
Phase-III, New Delhi 110020

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No C- 103, Okhla Industrial Estate Phase-III, New Delhi 110020

Sir,

This has reference with letter received through Outdoor diary no 8293 dated 06/11/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.11.2023 in the presence of Mr. Sudip Chatterjee) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke ventilation system provided but found not functional.
2. First aid hose reel provided but found nonfunctional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Internal hydrant provided but found nonfunctional.
5. Fire Pumps are not on auto mode.
6. Temporary structure at terrace level is not allowed

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours, faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg) SDMC Jal Vihar, Lajpat Nagar, New Delhi 110024.