

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

e/15

No. F6/DFS/MS/School/WZ/2023/ 589

Dated: 15 / 12/2023

To,

The Principal,
Govt. Co-ed Senior Secondary School,
Industrial Area, Karampura,
New Delhi:-110015.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Govt. Co-ed Senior Secondary School, Located at Industrial Area, Karampura, New Delhi-110015.

Sir,


Please refer to your Email dated 23/11/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 06/12/2023 in presence of Sh. Harish Kumar (Vice Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running at Ground plus three upper floors in a building comprised of Ground plus Three upper floors. However, the following Shortcomings were observed.

1. First Hose reels are provided but nozzles are missing at some places.
2. Terrace fire pump of 450 lpm is provided but not on auto mode.
3. Exit signage's are found missing at some places.

In view of above Shortcomings the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,


(Atul Garg)
Director
D/c

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.