



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F-6/DFS/MS/2023/Residential/ 4456

Dated: 18/12/2023

To,

Dr. Saudan Singh (Dean)
NDMC Medical Collage, Hindu Rao
Hospital, Malka Ganj, Delhi-110007.

Sub:- Regarding issuance of Fire Safety Certificate in r/o Hostel Block for Boys & Girls, NDMC Medical Collage, Hindu Rao Hospital, Malka Ganj, Delhi-110007.

Sir,

Please refer to your letter No. North DMC MC/2023/D/736 dated 18.10.2023 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 11.12.2023 in the presence of Sh. Sunil Jain (AE. Civil), Sh. Aman Shrivastava (Je. Electrical) to verify the status of the shortcomings already issued by this department vide letter No. F6/DFS/MS/2021/2494 dated 30.11.2021 and status is as under: -

S No.	Shortcomings	Status
1.	The width of 06m internal road and 09m turning radius at one side is obstructed by erecting cemented wall and three trees	Not Complied
2.	Only one staircase continues from ground to terrace level and second staircase provided at ground to six floors only the both staircase required from ground to terrace level.	Complied
3.	Fire check door not provided at some places in staircases.	Complied
4.	Public Address System provided but not functional.	Complied
5.	Exit signage and lifts signage's not provided at some strategic location in the building.	Not Complied
6.	Two lifts are proposed to be provided from ground to six floors but not functional at the time of inspection.	Complied
7.	Standby power supply not provided.	Complied
8.	Pressurization system is not provided in staircases lift shafts & lobby's.	Complied
9.	Electrical panel are installed in lift lobby which is required to be enclosed with fire doors.	Complied

Keeping in view of above observations, the said building is not safe from fire safety point of view. Hence, you are hereby advised to comply the observations at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non-compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(Atul Garg)
Director
Ph:-011-23414000

13/12/23