

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2023/SZ/ 606
To

Dated: 14/12/2023

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s HOTEL KIAN at L-316, Mahipalpur Extn. NH-8, New Delhi 110037

Sir,

This has reference with **MHA Portal ID 2023111418473 dated 15-11-2023** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 08.12.2023 in the presence of Ms. Sonali Sharma of the Guest House to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation:

1. The Fire Check doors not provided as per clause 7.31 of UBBL.
2. The occupancy above 3rd floor not acceptable as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(APUL GARG)
DIRECTOR

DELHI FIRE SERVICE

dm