

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2023/SZ/ 584

Dated: 14/12/2023

To,

The Principal,
K.R. Mangalam World School,
H-Block, Vikaspuri, New Delhi-110018.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s K.R. Mangalam World School, H-Block, Vikaspuri, New Delhi-110018.

Sir,

This is in reference to your letter No. Nil dated 19/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 29/11/2023 in presence of Sh. N.K.Singh (Admin. Officer). During the course of inspection it was observed that the building is comprised of ground floor plus three upper floors. The following shortcomings were observed:-

1. First aid hose reel system provided but not functional.
2. Automatic Sprinkler System provided in basement but not functional.
3. Fire pump having 450 provided but not functional.
4. Exit signage's provided but not sufficient.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service


Copy:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.