



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/EH/669

Dated 13/12/2023

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Pizza Hut (A Unit of Ms Devyani International LTD.) located at Shop No. 29, Ground Floor, Block-6, Shakti Nagar, Delhi- 110007.


Sir,

This has reference to online mha portal I'd No. 2023112918972 dated 01.12.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 07.12.2023 in the presence of Mrs. Megha (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has been observed that the building/ premise is comprised of basement, ground & 03 upper floors but (Restaurant proposed at ground floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

- 1 There are two exit doors having width of 1.90m & 80cm provided against requirements of 1.50m each. The second exit door is also not qualifying the requirement of safe means of escape as this escape route is through the kitchen area of the restaurant.
- 2 First aid hose reel hose not provided.
- 3 Internal hydrants not provided.
- 4 Terrace level fire pumps capacity of 450lpm provided but not functional.
- 5 Terrace level fire water tank capacity of 10,000ltrs provided against the requirement of 20,000ltr.
- 6 Exit signage's not provided in the restaurant.
- 7 Standby power supply not provided in the restaurant.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully


(Atul Darg)
Director
Ph: 011-23414000


11/12