

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/672

Dated 15/12/2023

To

The Dy. Health Officer, (Najafgarh Zone)
Public Health Officer,
Dhasa Bus Stand, Najafgarh,
New Delhi 110043

Sub: - Regarding issuance of fire safety certificate in r/o M/s Platinum Restaurant at 137/9 Aruna Asaf Ali Marg, Kishangarh, New Delhi 110070

Sir,

This has reference to your **MHA Portal 2023102317647 dated 02/12/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 11.12.2023 in the presence of Mr. Chander (accountant) to verify the fire safety measures installed in the building and observed that restaurant running at ground & Mezzanine floor only. During inspection, following points were observed:

- 1 There are two staircase having width of 1.50 mtr & 1.20 mtr against the required width of 1.50 mtr each.
- 2 First aid Hose reel provided but found nonfunctional.
- 3 Internal Hydrant not provided.
- 4 Terrace level Fire Pump capacity of 450 LPM provided but found not functional.
- 5 Dedicated overhead tank capacity 5,000 ltrs provided against the required capacity of 20,000 ltrs.
- 6 Exit Signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Joint Commissioner of Police, Lic/Branch, 1st Floor, P S Defence Colony, New Delhi -110049. For taking necessary action on the matter.