

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

NEW DELHI- 110001

No. F.6/DFS/MS/Hospital/2023/SZ/ 4458
To

Dated: 18/12/2023

Mr. Kuldeep Sharma,
Rosewalk Healthcare Pvt Ltd at
N-88, Panchsheel Park, New Delhi 110017

Sub: Regarding issuance of FSC in r/o Rose walk Healthcare Pvt Ltd at N-88, Panchsheel Park, New Delhi 110017.

Sir,

This has reference to your letter no nil dated 24/11/2023, received through Outdoor diary no 10041 dated 24/11/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.12.2023 in the presence of Mr. Mukesh (Security) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Temporary structure at terrace level is not acceptable.
2. Temporary office at basement level under the staircase not allowed need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE