



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7  
 आपदा निवारण  
 अमृत महोत्सव

No. F6 /DFS/MS/Industrial/SZ/2023 / 4459

Dated: 18/12/2023

To,

The Owner/occupier,  
 M/s Sonal Udyog (P) Ltd.,  
 Plot no. B-2/85, MCIE, Mathura Road, New Delhi.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Sonal Udyog (P) Ltd., located at Plot no. B-2/85, MCIE, Mathura Road, New Delhi.**

Sir,

With reference to the your letter no. nil dated 20.11.2023 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 07.12.2023 in the presence of Mr. Yogesh (Owner representative) and it was observed that the building is comprised of Basements + Ground + 02 upper floors. During the inspection following shortcomings were observed:

1. Fire check door (FCD) found removed.
2. No permanent provision to approach the pump room has been provided.
3. No ventilation provision in basement.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.

11.12.23