

c/91

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2023/WZ/582

Dated: 14/12/2023

To,

The Principal,
MRG Public School,
Run by St. Kabir Educational Society,
Pocket-B-5, Sector-3, Rohini,
Delhi-110085.

Sub: Issue of FSC in r/o MRG Public School, run by St. Kabir Educational Society located at Pocket-B-5, Sector-3, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 19.09.2023 received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 24.11.2023, in presence of **Mr. Vineet Kumar (Admin officer)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Pump house & its access found overhaul.
2. The required exit signage are not provided.
3. Fire tender path found reduced by 1.0 mtr on one corner side of swimming pool.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard.

The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.w.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph: 011-23414000