

c/2).

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2023/SZ/ 581

Dated: 14/12/2023

To,

The Principal,
Vrindavan Public School,
WZ-415, Hastal Village, New Delhi-110059.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Vrindavan Public School, WZ-415, Hastal Village, New Delhi-110059

Sir,

This is in reference to your letter No. 101/23 dated 26/10/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 08/12/2023 in presence of Sh. Satish Kumar Tyagi (Manager). During the course of inspection it was observed that the building is comprised of ground floor plus two upper floors. The following shortcomings were observed:-

1. First aid hose reel system provided but not functional.
2. Fire pump having 450 lpm provided but not functional.
3. Exit signage's provided but not sufficient.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.