

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2023/SZ/677  
To

Dated: 19./12./2023

The Dy. Health Officer, MCD,  
Public health Department,  
Aurobindo Marg, Green Park,  
New Delhi 110016

**Sub:** Regarding issuance of FSC in r/o M/s Gola Sizzlers Pvt Ltd, located at T-318,  
3<sup>rd</sup> Floor with Mezzanine, ambience Mall Vasant Kunj, New Delhi 110070.

Sir,

This has reference with **MHA Portal ID No 2023120119067** dated **01/12/2023** on the subject cited above. In this connection, it is to inform you that the site was visited by the officer concerned of this department on 08/12/2023 to verify the fire safety measures installed in the building and observed that the restaurant is running at Third floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The exit door having width of 1.50 mtr against the required two exit doors having width of 2m each.
2. The plan uploaded over MHA Portal is not matched with the existing layout of the restaurant.

Keeping in view of above observation, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

214 ✓