

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2023/ 676

Dated:-.19.1.2023

To,

The Manager
M/S Regent Restaurant, N-18,
Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Regent Restaurant, N-18, Connaught Place, New Delhi.

Sir,

This has reference to online ID No. 2023113019004 dated 30.11.2023, on the subject cited above, it is to inform you that the site was inspected by the officer concerned department on 11/12/2023 in the presence of **Manager** and the following shortcomings were observed:-

1. First aid hose reel & sprinklers found nonfunctional.
2. Pump found removed.
3. MOEFA found nonfunctional.

In view of above, the case is rejected and Fire Safety Certificate cannot be renewed.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

The Joint Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.