

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2023/ 4462

DATED: 18/12/2023

To,

The President,
M/S Sanghmitra CGHS Ltd.
Plot No-20, Sector-04, Dwarka,
New Delhi-110078.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o M/S Sanghmitra CGHS Ltd. Located at Plot No-20, Sector-04, Dwarka, New Delhi-110078.

Sir,

Please refer to your letter No. nil dated 05/12/2023 on the subject cited above. In this connection it is to inform to you that the above said premises was re-inspected by the officer concerned of this department on 11/12/2023 in the presence of Sh. Sujeet Kumar (Guard) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building fund encroached.
2. Two fire extinguishers must be provided near each riser/down comer in each block.
3. Hose Reels & Hydrants system found nonfunctional.
4. PA system found nonfunctional.
5. MOEFA found Non functional.
6. All the Pumps at terrace level found nonfunctional.
7. Exit signage found removed at some places.
8. Communication system in lift car found removed.
9. Dully fill form J & K are not submitted.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.