

45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2023/612

Dated: 19-12-2023

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Al-Tauheed Guest House situated at 3371-72-73 and 3374 Netaji Subhash Marg, Darya Ganj, Delhi-06.

Sir,

This has reference to online application I.D. no. 2023120119076 dated 01.12.2023 on the subject cited above. It is to inform you that the guest house was inspected by the officer concerned from this department on 12.12.2023 in the presence of Mr. Dilip Kumar (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm which are required as per gazette notification dated 27.05.2019, not provided.
2. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service o/c
Tel: 011-23414000

Copy to:-

The Licensee,

Al-Tauheed Guest House at 3371-72-73 and 3374, Netaji Subhash Marg, Darya Ganj, Delhi -06.