

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/Business/SZ/2023/212

Dated: 13/10/2023

To,

The Executive Engineer (Bldg.) HQ South Delhi Municipal Corporation, 9th Floor, Civic Centre, Minto Road, New Delhi – 02.

Ref: JSI, MCD Portal Online Case ID – 10116990. Sub: Issuance of Fire Safety Certificate for OCC.

Sir,

With reference to the case mentioned above it is informed that JSI was conducted by a joint team of DFS and MCD (Bldg.) in presence of Sh. Upendra Nath Marwah (Owner) on 10.10.2023 and following shortcomings were observed in the building as mentioned below:

- Installation of the lifts is still under process. Hence lift lobby and lift shaft pressurisation and lift related fire/ life safety requirements could not be checked properly.
- 2. Fire Protection System in electrical meter(s) and panels found not provided.

Hence this case is rejected.

Yours Faithfully

Director

Delhi Fire Service

of lh w

Copy to:

1. The Authorised Signatory, M/s Plot No. I-4, Block B-1, Mohan Cooperative Industrial Estate, New Delhi.