

C-37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/BNQT/NDZ/2023/262

Dated: 22/12/2023

To,

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s Malik Banquet Hall situated at Prop. No. 242, Fasil Road, Delhi Gate, Delhi - 110006.

Sir,


This has reference to your online application I.D. no. 2023120719307 dated 07.12.2023 on the subject cited above. In this connection, it is to inform you that the building /premises was visited by the team of officers from this department on dated 15.12.2023 in the presence Mr. Jalaluddin (Owner) and it was observed that the building is comprised of Ground + 01 upper floor. During inspection, following shortcomings were observed:

1. 02 no. of staircase exists but one staircase only up to 1st floor which is required to be provided with ^{up to} terrace level. ^{for smoke venting}
2. Exhaust fans are not provided.
3. MOEFA not provided.
4. Public address system not provided.
5. Water storage tank provided for 20,000 ltr. against the requirement of 25,000 ltrs.
6. Fire pump provided of capacity 450 LPM against the requirement of 900 LPM.
7. Exit signages are not provided.

In view of above shortcomings, the occupancy of the building /premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The owner/ occupier is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service
Tel:-011-23414000

Copy to:-

The Manager, Malik Banquet Hall at Prop. No. 242, Fasil Road, Delhi Gate, Delhi - 110006.

22/12/2023