

No. F6/DFS/MS/WZ/2023/ 254

Dated:- 21 / 12 / 2023

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit,
Police Station, Defence Colony,
New Delhi.

Sub.:- Regarding issuance of Fire Safety Certificate in respect of M/s. Pizza Hut (A Unit of Ms Devyani International Ltd.) located at A-6/10, Ground Floor, Paschim Vihar, New Delhi-110063.

Sir,

This has reference to online application no. 2023112818947 dated 28/11/2023 on the subject cited above. In this connection, it is to inform you that the above said building has been inspected by the officer concerned of this department from fire safety point of view on 13/12/2023 in the presence of Sh. Ajay (Manager). to check the shortcomings already pointed out by this department vide letter no. F6/DFS/MS/EH/2020/319 dated 19.03.2020.

The statuses of shortcomings are as under:-

S. no.	Shortcomings	Status
1.	Doors of 2.0 mts width are not provided (1.5 m each Provided)	Rectified
2.	Hose Reel Hose not provided	Provided but non-functional
3.	Fire Pump capacity of 450 LPM not provided	Provided but lack of access could not checked.
4.	20,000 ltrs capacity of overhead tank not provided	Not accessible
5.	MOEFA (Manual Operated Electric Fire Alarm) is not provided.	Provided
6.	Down Comer System not provided	Provided

In addition to the above shortcomings, the following shortcoming also observed:-

1. Fire check door is not provided in the kitchen.

In view of the above, the application for issuance of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. Sh. Abhishek Mittal, M/s. Pizza Hut (A unit of Ms Devyani International Ltd.), A-6/10, Paschim Vihar, New Delhi-110063