

c/62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6 /DFS/MS/BNQT/NDZ/2023/ 263

Dated: 22/12/2023

To,

Mr. Shyam Saini,  
M/s R.A Enterprises,  
Property No. A8, Ground floor,  
Khasra No.136, Khatauni no. 31,  
Main Road Ghazipur Village, Delhi-110096

**Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s R.A Enterprises, located at Property No. A8, Ground floor, Khasra No.136, Khatauni no. 31 Main Road Ghazipur Village, Delhi-110096.**

Sir,

This has a reference to your application No. 202312019152 dated 04/12/2023 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 08.12.2023 in the presence of Mr. Shyam Saini (Owner) and observed that building comprised of ground floor plus one upper floor only.

**Following shortcomings were observed during time of inspection:**

1. Entry / Exit doors are in one direction only and depth of the building is more than 50 meters, which does not meet the travel distance.
2. Approach to first floor i.e. Alternate staircase is through banquet hall only which is not acceptable.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

o/c @

Copy to:-

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t.-MHA portal ID- 202312019152 dated 04/12/2023.