



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2023/WZ/ 4485

Dated: 22/12/2023

To,

Sh. Akash Goel,
M/s Dipanshu Cosmetics,
D-59, Sector-2, DSIIIDC Bawana,
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Dipanshu Cosmetics located at D-59, Sec-2, Bawana Industrial Area, Delhi-110039.

Sir,

This has reference to your e mail id dated 08/12/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 18.12.2023 in presence of Sh. Akash Goel to verify the fire safety arrangement provided there in.

During the course of inspection it was observed that the building comprised of Basement, Ground, Mezzanine & Two upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. There is only one staircase provided against the requirement of 02 Staircases.
2. Width of staircase found 1.10 m against the required width of 1.50 m each.
3. Width of exit door is less than the required width of 1.50 m.
4. Fire check doors found not provided.
5. Automatic sprinkler system found not covering the whole basement and not provided at mezzanine floor and second floor.
6. Terrace level pump not found in auto mode.
7. Exit signage's found not provided at some strategic locations.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully


(Atul Garg)
Director
Ph. 011-23414000

Copy to:-

1. Sh. Akash Goel, H.No. 212, Sector-5, Gurugram, Haryana.
2. Sh. K.R. Chawla, Dy. Drugs Controller/ Licensing Authority, Drug Control department, F-17, Karkardooma, Delhi- 110032.