

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/684

Dated 26/12/2023

To

The Dy. Health Officer,
Public Health Department, MCD,
Aurobindo Marg, Green Park,
New Delhi 110016.

Sub: - Regarding issuance of fire safety certificate in r/o 7OT Old Town Pub Cafe (A unit of Aura Entertainment and Hospitality) situated at Khasra Sakhni No 25, First floor, Kalu Sarai, 7 Mehrauli Road, New Delhi 110016.

Sir,

This has reference to with **MHA Portal ID 2023120219103 dated 04/12/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 19.12.2023 in the presence of Mr. Harish Panday to verify the fire safety measures installed in the building and observed that restaurant running at First Floor only. During inspection, following points were observed:

1. First Aid Hose reel hose provided but found not working.
2. MOEFA provided but found not working.
3. Internal hydrants provided but found not working.
4. Terrace level pump capacity 450 LPM provided but found not functional.
5. Overhead tank capacity 5,000 ltrs provided against the required capacity 20,000 ltrs.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Atul Garg