

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



elub

No. F6/DFS/MS/WZ/2023/ 606

Dated:- 22/12/2023

To,

The Principal,
Bhatnagar International Summit,
A-1, Paschim Vihar,
New Delhi.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Bhatnagar International Summit, located at A-1, Paschim Vihar, New Delhi.

Sir,

Please refer to your email dated 30/11/2023 on the subject cited above. In this connection, it is to inform you that the said building have been inspected by the officer concerned of this department on 14/12/2023 in the presence of Ms. Isha Yadav (Principal) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/WZ/2023/366 dated 31/08/2023.

During the course of inspection, it has been observed that the school management has rectified some of the shortcomings, the status is under as:-

<u>S. no.</u>	<u>Shortcomings</u>	<u>Status</u>
1.	Tin Shed Rooms on the terrace must be removed/dismantled	Not yet rectified
2.	Only one staircase of width 1.4 m is provided Ground to 1 st floor. One more staircase of width 1.5 m required to be provided from Ground Floor to Terrace	Not yet rectified
3.	Fire protection system such as Fire Pumps, Hose Reel Hose and Sprinkler in Basement were found nonfunctional	Rectified
4.	Over Head Tank found empty	Rectified

In the addition of above shortcomings, the following shortcomings also observed:-

1. Basement is divided in rooms, which are using for children classes. As per UBBL/NBC-2016 class rooms are not allowed in the basement.
2. Stage made of wooden in the basement to be removed.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,


(Anil Garg)
Director
15/12/23

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.