



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2023/614

Dated: 22-12-2023

To

The Principal,
 D.S. Modern Public School,
 Main Sindhu Farm Road, Mithapur Extension,
 Badarpur, New Delhi-110044.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **D.S. Modern Public School, located at Main Sindhu Farm Road, Mithapur Extension, Badarpur, New Delhi-110044.**

Sir,

With reference to your letter no. 06/005 dated 17.10.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.12.2023 in the presence of Mrs. Monika Sharma (Principal) and it was observed that the school building is comprised of Ground + 1 upper floors. During the inspection following shortcomings were observed:-

1. Hose reel found not functional.
2. Fire pump having capacity 220 LPM & head 40 mtrs. found not functional.
3. Overhand tank capacity 1,000 liters provided against the requirement of 2,500 liters for exclusively for firefighting.
4. Exit signages found not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
 Director

Delhi Fire Service

DL
 19/12/23

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.