

C/93



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2023/607

Dated:- 22-12-23

To,

The Principal,
Govt. Co-ed. Sr. Sec. School (ID-1617029),
Bakkarwala, New Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Co-ed. Sr. Sec. School (ID-1617029), located at Bakkarwala, New Delhi-110041.

Sir,

Please refer to your email dated 10/11/2023 on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 13/12/2023 in the presence of Sh. Suresh Kaushik (PGT Teacher). During inspection, it has been observed that the school building is comprised of 03 blocks - Ground + .03 Upper floors. Fire Safety arrangements such as fire extinguisher, first aid hose reel, fire pumps, & overhead water tank etc found provided. However the following shortcoming has been observed:-

1. ABC & CO₂ type of Fire Extinguishers found non-functional in each block.
2. First-Aid Hose Reels is provided but found non-functional in each block.
3. Terrace pumps 450 lpm capacity are provided but found non-functional in each block.
4. Exit signages are inadequate in each block.
5. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.