



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C/6 DDA/ST
75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2023/615

Dated: 22-12-2023

To

The Principal,
M/s Holy Angel's Public School,
345, Ratan Singh Marg, Meethapur,
Badarpur, New Delhi-44.

Sub:- Regarding issuance of Fire Safety Certificate in respect of M/s Holy Angel's Public School located at 345, Ratan Singh Marg, Meethapur, Badarpur, New Delhi-44.

Sir,

With reference to your letter no. HAPS/072023 dated 28.07.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.12.2023 in the presence of Mrs. Sangeeta Sharma (Principal) and it was observed that the school is running at Ground + 1 upper floor of the building which is comprised of Ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. Alternate staircase having width not less than 0.75 meters is required.
2. Exit sinages found not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Center Zone: Lajpat Nagar, New Delhi-110024.

22/12/23