

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 688

Dated: 27/12 /2023

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Lite Bite Foods Pvt Ltd
(Punjab Grill) at Ground & First Floor, Plot No M-82, Greater Kailash Part - II,
Market, New Delhi 110048

Sir,

This has reference to with **MHA Portal ID 2023112918990 dated 11/12/2023** on the subject above. In this connection, it is to inform you that the premise has already been visited by the concern nominated authority of this department on 12/12/2023 in the presence of Mr. Nawaz (Manager) to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. There are two exit door having width of 1.10 mtr & 1.40 mtr against the required width of 1.50 mtr as per UBBL-2016.

The same observations has already been issued and communicated earlier by this department vide letter of even no 674 dated 18/12/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

dit v