



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

cl28



No. F6/DFS/MS/2023/School/ 621

Dated: 27/12/2023

To,

The Principal  
M.C. Primary Boys School,  
Libaspur, Delhi-110042.

**Sub:-** Regarding grant of fire safety certificate in r/o M.C. Primary Boys School (School I'd No-1253165) located at Libaspur, Delhi-110042.

Sir,

Please refer to your letter received through online e-mail dated: 20.11.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 18.12.2023 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 03 blocks, one block comprised of ground floor (damaged condition & not in used) & two blocks comprised of ground + first floor only. At the time of inspection Mr. Naresh Kumar (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. There is 02 nos. of staircases provided in old block width of 1.40m & 1.50m against the requirement of 1.50m each.
2. Exit signage's found removed at strategic locations in the school building.
3. Electrical meters & mcb box are installed inside the stairwell, which need to be removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Sd/-) (Signature)  
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 110054.

720  
22/12