

C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2023/624

Dated.29.12.2023

To,

The Principal,
M.C.D. Co-Edu. School,
Bagh Kare Khan, Kishan Ganj,
New Delhi.

Sub: Regarding issuance of FSC in r/o M.C.D. Co-Edu. School, Bagh Kare Khan, Kishan Ganj, New Delhi.

Sir,

This has reference to your letter no. Nil dated 10.10.2023, on the subject cited above. In this regard, it is to inform you that the site was inspected on dated 14.12.2023 by the officer concerned of this department in presence of **Principal** and following shortcomings were observed.

1. Alternate staircase is not serving up to second floor.
2. PA system found nonfunctional
3. Terrace pump not in auto mode provision.

In view of above, FSC can't be issued till the compliance of the same.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :

1. Director of Education, old secretariat, New Delhi.