

e/24.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2023/ 605

Dated: 22 / 12 / 2023

To,

The Principal,
MCD Primary Pratibha Co-ed School
Palam Village New Delhi - 110045.

**Subject: Renewal of Fire Safety Certificate in r/o MCD Primary Pratibha Co-ed School
Located at Palam Village New Delhi - 110045 (School Id-1757198).**

Sir,


Please refer to your letter No. nil dated 25/11/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 06/12/2023 in the presence of Mrs. Mukesh Sehrawat (Principal) from fire safety point of view.

The following shortcoming was observed during the time of inspection:-

1. Hose reel hoses found nonfunctional/removed..
2. Terrace pump found nonfunctional.
3. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.