



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2023/ 264

Dated 27/12/2023

To,

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049.

**Subject: Issuance of Fire Safety Certificate in respect of MG Banquet Hall (A unit of MG Banquet) Located at Plot No. 6 Block C, Khasra No. 31 34 12 Matiala Extn. New Delhi.**

Sir,

Please refer to online application No. 2023120819340, dated 11/12/2023 on the subject cited above. In this regard, it is to inform that the said premises have been inspected by the team of officers concerned of this department on 21/12/2023 in presence of Ms. Smita Jha (Manager) from fire safety point of view.

**The following shortcoming was observed during the time of inspection:-**

1. Fire Check Doors found not provided.
2. Smoke management system found not provided in staircases at upper floors.
3. Manually operated fire alarm system is provided but found nonfunctional.
4. PA system found nonfunctional.
5. Hose reel hoses & hydrants found nonfunctional.
6. All the pumps at ground level are found nonfunctional and not accessible.
7. Terrace pump of 450lpm capacity found not provided
8. The dimension of the underground fire water tank must be informed.
9. Terrace fire water tank of 10000 ltr capacity found not provided.
10. Exit signage is not provided at some places.
11. Lift Signage are found not provided at some places.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. The applicant may be advised to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
Director,  
Delhi Fire Service.

Copy to:-

1. The Manager, MG Banquet Hall (A unit of MG Banquet) Located at Plot No. 6 Block C Khasra No. 31 34 12 Matiala Extn. New Delhi.

Ok  
28/12