

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2023/ 4518

DATED: 28 /12/2023

To,

The President / Secretary  
Prodhygiki CGHS Ltd.  
Plot No-11, Sector-03, Dwarka,  
New Delhi-110078.

**Subject: - Renewal of Fire Safety Certificate in r/o Prodhygiki CGHS Ltd. Located at Plot No-11, Sector-03, Dwarka, New Delhi-110078.**

Sir,

Please refer to your email, dated-15/12/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been re-inspected by the officer concerned of this department on 21/12/2023 in the presence of Sh. Balwant Singh (Manager) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found encroached.
2. Only one ABC type fire extinguisher of 4 kg capacity found provided at each floor against required two fire extinguishers.
3. Hose reel & Hydrants found nonfunctional.
4. MOEFA found nonfunctional.
5. P.A. System found nonfunctional.
6. Terrace pumps found nonfunctional.
7. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
(Director)  
Delhi Fire Service

Copy to:-

✓ The Joint Director, DDA, Vikas Sadan, INA, New Delhi.