

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2023/616

Dated: 22-12-2023

To

The Principal,
Rajkiya Pratibha Vikas Vidyalaya,
Civil Lines, Delhi - 110054.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Rajkiya Pratibha Vikas Vidyalaya, Civil Lines, Delhi 110054 (School ID - 1207113).**

Sir,

This has reference to letter outdoor diary no. 10091 dated 28.11.2023 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 15.12.2023 in the presence of Mr. Virender Singh (Estate Manager). During the inspection, following shortcomings were observed:-

1. Hose reel found but not functional.
2. Fire pump not in auto start mode.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,


(Atul Garg)

Director

Delhi Fire Service o/c

Tel: 011-23414000
20/12

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi