

c/37

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2023/612

Dated: 22/12/2023

To,

Smt. Nutan (Principal)  
Sai Public School,  
WZ-86A, Todapur Village, New Delhi-110012.

Subject: Renewal of Fire Safety Certificate in r/o Sai Public School Located at WZ-86A, Todapur Village, New Delhi-110012.

Sir,

Please refer to your letter No. 263/SPS/Corspndnc/FY/2023-2024, dated 06/12/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned on 18/12/2023 in the presence of Smt. Babita (Cashier) from fire safety point of view. The school was found running at Ground, 1<sup>st</sup> 2<sup>nd</sup> floor.

**The following shortcomings were observed during the inspection:-**

1. The school is not accessible for fire tender.
2. Two staircases of 120cm & 55cm width found provided against required two staircases of 1.5 m clear width.
3. Width of class room doors found varies from 80 cm to 90cm, all the class room doors must have 100 cm clear width.
4. The width of Corridors/ passages lead to stair must not be less than 1.5m.
5. Exit Signage found not provided.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
(Director)  
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi - 110054