



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

c/s.



No: F.6/DFS/MS/School/2023/WZ/ 602

Dated: 22/12/2023

To,

The Assistant Engineer (E),
PWD Sub-Division 2,
Edu. Elect. Edn. I Div. (N)
Sector-16, Rohini, Delhi-89.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Sarvodaya Co-ed Vidyalaya (ID- 1411021), New Building located at A- Block, Keshavpuram, Delhi-110035.

Sir,

This has reference to your email id dated 01.12.2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 15.12.2023 to ascertain the availability and operability of the fire prevention and fire safety measures, Sh. Narender Deswal (Estate Manager) was present at the time of inspection.

During the course of inspection it was observed that school building is comprised of Ground plus Three upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. Fire extinguishers not provided.
2. First aid hose reels provided but not functional.
3. Terrace level fire pump provided but not functional.
4. Exit signage's not provided.
5. Form 'I' not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

Atul Garg
20/12/23

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.
2. Principal, Sarvodaya Co-ed Vidyalaya (New Building), A- Block, Keshavpuram, Delhi-35.