

c/61

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/School/2023/SZ/ 617

Dated: 22-12-2023

To,

The Principal,
Sarvodaya Kanya Vidyalaya No.-2,
Sagarpur, New Delhi.

Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya No.-2, Sagarpur, New Delhi.

Sir,

Please refer to your letter No. SKV-II/SP/765 dated 23/11/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on 18/12/2023 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Smt. Nivedita Sachdeva (Principal) was present and it was observed that the building is comprised of A & B block (SPS Block) G+3 upper floors & 3 blocks G+1 floor and have following shortcomings.

1. Fire extinguishers provided but not functional.
2. First aid hose reels are provided but not functional in A & B block (SPS Block).
3. Fire pumps are provided but not functional in A & B block (SPS Block).
4. Exit signage's are provided but not sufficient.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.