

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/EH/2023/SZ/ 686

Dated: 27/12/2023

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: -Regarding issuance of Fire Safety Certificate in r/o M/s THEOS Food Pvt Ltd
located at M-23, Ground Floor, Greater Kailash -II, New Delhi 110048

Sir,

This has reference to with **MHA Portal 2023120119065 dated 06/12/2023** on the subject above. In this connection, it is to inform you that the premise was inspected by the concern officers of this department on 19/12/2023 in the presence of Mr. Akash (Manager) to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. There are two exit door having width of 1.0 mtr & 1.40 mtr against the required width of 1.50 mtr as per UBBL-2016.
2. Terrace level fire fighting pump and water tank could not be checked due to not accessible /terrace door under lock and key.
3. Electrical Meter installed in main exit is not acceptable, may be shifted to another safe place.

The same observations has already been issued and communicated earlier by this department vide letter of even no 633 dated 21/11/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE