



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

2/17

No.F6/DFS/MS/School/SZ/2024-01

Dated: 03-01-2024.

To

The Principal,
M/s Real View Public School,
F-532 & 533, Jaitpur Extension-II,
Kalindi Kunj Road, New Delhi-44.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Real View Public School located at F-532 & 533, Jaitpur Extension-II, Kalindi Kunj Road, New Delhi-44.

Sir,

With reference to the letter no. nil dated 05.12.2023 on the subject cited above, it is informed that the said building was inspected by the officer concerned of this department on 18.12.2023 in the presence of Mrs. Neelam Kumari (Headmistress) and it was observed that school building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. Hose reels found not functional.
2. Fire pump found not functional.
3. Exit signages found not provided.

In view of above shortcomings, the application renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

19/12/23

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.