

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

c/38

No. F6/DFS/MS/School/WZ/2023/ 02

Dated: 03/01/2024

To,

The Principal,
S.M. Arya Public School
Road No. 45, Punjabi Bagh (West),
New Delhi-110026.

Sub: - Regarding Renewal of Fire Safety Certificate in r/o S.M. Arya Public School located at Road No. 45, Punjabi Bagh (West), New Delhi - 110026.

Sir,

Please refer to your Email dated 24/11/2023 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 12/12/2023 in presence of Sh. Captain Laxmi Narayan (Care Taker) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is running in Two Blocks, B-1=Ground + 02 upper floors & B-2 = Ground +1 upper floor (Nursery wing) both are inter connected & Basement (approx 40 yard²) near assembly ground was issued FSC vide letter no. F6/DFS/MS/School/WZ/2020/462 dated 03/11/2020. Fire Safety arrangements such as Fire Extinguishers, First-Aid Hose reel, Terrace pump, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Smoke Management System is provided but not functional.
2. First-Aid Hose Reels are provided but found damage.
3. MOEFA is provided but not functional.
4. Public Address System is provided but not functional.
5. Terrace level pump capacity of 450lpm & 180lpm is provided but not functional.
6. Overhead water storage tank 10,000ltr provided but found empty.
7. Exit Signages found removed at some places.



In view of above Shortcomings the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,


(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

 
15/12/2023