

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ 1

Dated:- 03/12/2024

To

The Manager  
M /S The COBRA,  
GF and FF, 21-22, 24/1, Plot no.-5/80A,  
Krishna Market, Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S The COBRA, Shop No.GF and FF, 21-22, 24/1, Plot no.-5/80A, Krishna Market, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2023121419527 dated 14-12-2023, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned department on 26/12/2023 in the presence of Manager and following shortcomings were observed:-

1. Hose reel & hydrant system found nonfunctional.
2. MOEFA found removed.
3. PA system found nonfunctional.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.