



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/9  
आजादी का  
अमृत महोत्सव

No. F6 /DFS/MS/Metro club/SZ/2023/ 04

Dated 04/01/2024

To

Shri Bhagwan (Sr. DGM/Electrical),  
Office of the Chief Electrical Engineer/UD  
Opp. Frank Anthony Public School,  
Lala Lajpat Rai Marg, Lajpat Nagar-IV, New Delhi.

Ref: DMRC/Fire/152/2023/12/330

Sub: Regarding issuance of Fire Safety Certificate for M/s Club House located at DMRC Sarita Vihar, Staff Quarters, F Block, New Delhi.

Sir,

With reference to online portal no. DMRC/Fire/152/2023/12/330 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 19.12.2023 in the presence of Mr. Vikram Singh Bahaduriya (AM/E &M DMRC Project) and it was observed that the building is comprised of Ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. The segregation of staircase lobby is not as per standards.
2. The electrical panels in the staircase lobby may either be relocated or shall be provided with fire suppression system.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

01/1/24

**Copy to:**

The JGM/E&M, DMRC Ltd., Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-01.