



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2024/03

Dated: 03/01/2024

To

Sh. Hit Lal (HoS),
Diwan Chand Arya Sr. Sec. School,
Lodhi Colony, New Delhi-110003

Sub: Regarding renewal of Fire Safety Certificate in r/o Diwan Chand Arya Sr. Sec. School, Lodhi Colony, New Delhi-110003

Sir,

This has reference to your letter received through outdoor diary No. 10893 dated 15/12/2023, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 27/12/2023 in your presence. During the course of inspection, the shortcoming observed is as below.

1. The hose reel hose found provide but non functional.
2. Terrace level fire pump found non functional.

In view of the above, the application for renewal of Fire Safety Certificate is rejected and you are advised to rectify the shortcomings under intimation to this department for further consideration.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054