

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



Dated: 05/ 01 /20214

No. F6/DFS/MS/WZ/2021/ 2 8 To,

Sh. Mohit Kumar Goel, Crystal Crop Protection Pvt. Ltd., B-95, Wazirpur Industrial Area, Delhi- 110052.

Sub: - Inspection report in r/o M/s. Crystal Crop Protection Pvt. Ltd., B-95, Wazirpur Industrial Area, Delhi- 110052.

Sir,

Please refer to your e-mail id dated 15/12/2023 on the subject cited above. In this connection, it is to inform you that the above said building was inspected by the officer concerned by this department on 28/12/2023 in the presence of Sh. Mohit Goel to see the compliance of shortcomings communicated vide this department letter No. F6/DFS/MS/2023/WZ/4267 dated 16/11/2023.

During the course of inspection following shortcomings have been observed and status is as under:-

Sr. No	Shortcomings	Status
1.	Staircase and lift are not segregated by fire check doors.	Not Rectified
2.	Alternate staircase is not opening on the terrace.	Not Rectified
3.	Electrical shafts provided in staircase are not segregated by fire check door.	Not Rectified
4.	Detectors not provided in cabin rooms.	Not Rectified
5.	MOEFA found provided but not functional.	Rectified
6.	Main electric pump & Diesel D.G. driven pump was not functional at the time of inspection.	Rectified
7.	The third floor is to be removed/ demolished or the third floor is to be regularized from the building sanctioning authority.	Not Rectified
8.	Ventilation system was not on auto mode.	Not Rectified
9.	Sprinkler system shall be extended in left out areas.	Not Rectified
10.	Temporary structure under the stairs of 2 <sup>nd</sup> basement shall be removed.	Not Rectified
11.	Garbage shall be removed from ventilation room.	Rectified
12.	Exit signages are not provided in 1st Basement.	Rectified

In view of the above shortcomings, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall is at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

Director Ph. 011-23414000